



Lelystad, 04-07-2018

Sentec International bv

Pascallaan 36
8218 NJ Lelystad
P.O. Box 2140
8203 AC Lelystad
The Netherlands
Phone: +31 320 26 78 26
sentecinternational.com


Declaration on the French VOC regulation DEVL 1104875A

In compliance with the French VOC regulation DEVL 1104875A Sentec International declares hereby that the Fresco Tex 350g and Fresco 290g wallcovering products have been tested according to the requirements of this regulation.

Emissions have been tested to the requirements on the labelling of construction, wall or floor coatings and varnishes on emissions of volatile organic compounds, based on the French regulation as published on March 25th 2011 (décret DEVL110903D) and on May 13th 2011 (arête DEVL 1104875A).

The preparations of the samples, tests and evaluations have been made according to the standards ICO 16000-9, -6, and -3.

The results of the test can be summarized as follows: The sample material fulfils the requirements for class "A+" after 28 days.



Tony de Ruiter

A blue ink handwritten signature of Tony de Ruiter, consisting of a stylized, cursive script.

Technical Manager